



NEC Consultants (Pvt.) Ltd.

Punjab Cities Governance Improvement Project

## Energy Audit & Energy Efficiency Improvement Program for WASAs in Punjab



REPORT  
Jhang Branch Canal Faisalabad

April 2016



**THE URBAN UNIT**  
Urban Sector Planning & Management Services Unit (Pvt.) Ltd.  
A Public Sector Company.



**THE WORLD BANK**  
IBRD • IDA | WORLD BANK GROUP



# Energy Audit & Energy Efficiency Improvement Program for WASAs in Punjab

March 2016

## **NEC Consultants Pvt. Ltd**

Perfect SITE, 22 KM Ferozepur Road, Near Gujju Matta Metro Bus Station, Lahore  
+92-42-35273741-46, [www.nec.com.pk](http://www.nec.com.pk)  
[necnorth@nec.com.pk](mailto:necnorth@nec.com.pk)

This study was assigned by **The Urban Unit, Punjab**

## DISCLAIMER

No part of this document may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, recording or information storage and retrieval system, without prior written permission of the USPMSU.

A publication of the Urban Sector Planning and Management Services Unit (Private) Limited, the opinion expressed in the document are solely those of the authors and publishing them does not in any way constitute an endorsement of the opinion by the USPMSU.

## ACKNOWLEDGEMENTS

This report has been prepared by The Urban Unit (Urban Sector Policy & Management Unit), P&D Department, Government of Punjab. The Urban Unit, under the Punjab Cities Governance Improvement Project (PCGIP)-DLI-4 is supporting WASAs for implementing Energy Audit Management Opportunities. Energy management opportunities have been extracted from the energy audits of WASA pumps.

### **The Team**

Dr. Nasir Javed  
Engr. Abid Hussainy  
Engr. Ali Raza  
Shafqat Ullah  
Muhammad Rizwan  
Kashif Shaukat  
Adnan Khan

### **Editing & Layout By:**

Ms. Madiha Qamar

### **Printed in Pakistan**

Copyright: Urban Sector Planning and Management Services Unit (Private) Limited.

## CONTENTS

Contents	4
List of Annexure	4
List of Figures	4
List of Tables	4
List of Acronyms and Abbreviations	5
Glossary	5
<b>1.0 Introduction</b>	<b>7</b>
1.1 Background	7
1.2 Methodology	7
1.3 Scope	8
<b>2.0 Energy Audit Findings</b>	<b>9</b>
2.1 Pumping system efficiency	9
2.2 Electricity consumption trend	11
2.3 Pumping system efficiency improvement potential	12
2.4 Interventions for the improvement of WASA stations	12

## LIST OF ANNEXURE

1	Energy Audit Reports
2	Selected Pictures

## LIST OF FIGURES

1	Pumping system efficiency category	11
2	Unit electricity consumption trend (tube wells)	12

## LIST OF TABLES

1	Detail of WASAs pumps	8
2	Detail of Jhang Branch Canal	9
3	Typical overall pumping system efficiency classification	10
4	Detail of motor loading and pumping system efficiency	10
5	Detail of water discharge and electricity consumption	11
6A	Interventions & investment required in WASA stations- Jhang Branch Canal	13
6B	Interventions & investment required in WASA stations- Jhang Branch Canal	15

## LIST OF ACRONYMS AND ABBREVIATIONS

<b>Bhp</b>	Brake Horsepower
<b>Cusec</b>	Cubic Feet per Second
<b>Ehp</b>	Electrical Horsepower
<b>Gpm</b>	Gallon Per Minute
<b>Hp</b>	Horsepower
<b>kVA</b>	Kilo Volt Ampere
<b>kW</b>	Kilo Watt
<b>kWh</b>	Kilo Watt Hour
<b>LESCO</b>	Lahore Electric Supply Company
<b>m/s</b>	Meter Per Second
<b>m<sup>3</sup>/hr</b>	Cubic Meter Per Hour
<b>MCB</b>	Fuses or Miniature Circuit Breaker
<b>Mm</b>	Millimeter
<b>MS</b>	Mild Steel
<b>Psig</b>	Pound Per Square Inch (Gauge)
<b>RPM</b>	Revolution Per Minute
<b>TDH</b>	Total Dynamic Head
<b>VFD</b>	Variable Frequency Drive
<b>WASA</b>	Water and Sanitation Agency
<b>Whp</b>	Water Horsepower

## GLOSSARY

<b>Discharge Pressure</b>	The pressure obtained at center line of pump discharge pipe using a calibrated gauge (psig). Discharge pressure is converted to feet and expressed as "Discharge Head".
<b>Brake Horsepower</b>	The output horsepower of a motor to a pump; may also be used to refer to the required input horsepower to the pump itself.
<b>Deep Well Turbine Pump</b>	A turbine pump installed inside a well casing below the pumping water level in the well.
<b>Discharge Head</b>	Head measured above center line of pump discharge pipe.
<b>Drawdown</b>	The measured distance that a well's water level changes from standing/static level to operating pumping level during observed test conditions.
<b>Dynamic Head</b>	The sum of the pressure and the pumping head developed by a pump
<b>Friction Head</b>	The head required to overcome the fluid friction in a pipe or water system
<b>Friction Losses</b>	Energy losses associated with moving water against rough surfaces. In water pumping applications, it is the water pressure lost as a result of contact between moving water and a pipeline or open channel.
<b>GPM per Foot Drawdown</b>	The ratio of capacity (GPM) to drawdown feet is useful in determining the well's performance.
<b>Head</b>	Alternate term for pressure. One pound per square inch (psi) = 2.31 feet of water head

<b>Overall Plant or Pumping System Efficiency</b>	The ratio of the water horsepower (the overall output of the plant) to input horsepower (the power input). The overall output can also be defined as the amount of horsepower required to deliver the measured capacity (water gallons per minute) and the measured total head.
<b>Pumping Water Level</b>	The well's operating water level below center line of discharge pipe as observed during test condition
<b>Static Water Level</b>	The well's water level obtained when pumping plant is at rest.
<b>Suction Head</b>	Head measured above center line of pump suction intake. Most often obtained with calibrated bourdon tube pressure gauge (suction pressure) and converted to feet by conversion factor 2.31 ft. water/psi
<b>Suction Lift</b>	The distance between pump discharge head and water level.
<b>Total Head</b>	The sum of the water head above and below the center line of the pump discharge pipe. For well applications, the Total Head is the sum of the Discharge Head and the Pumping Water Level. Total head is used in determination of water horsepower and pump performance.
<b>Water Horsepower</b>	The output horsepower of a water pump. It is the combination of flow rate and pressure.

## 1.0 Introduction

### 1.1 Background

Government of the Punjab, Pakistan with financial assistance from the World Bank, is implementing “Punjab Cities Governance Improvement Project (PCGIP)” for strengthening systems for improved planning, resource management, and accountability in five large cities of Punjab i.e. Lahore, Faisalabad, Multan, Gujranwala and Rawalpindi.

The project utilizes a result-based approach and, consistent with this focus, the disbursement decisions to the city and its entities are based on achievement of pre-specified results, referred to as Disbursement linked Indicators (DLIs) which reflect priority elements in furthering the Government’s urban agenda, critical at the provincial level, within the existing legislative, regulative and policy framework of the Government. DLIs includes intermediate outcomes, incremental steps and results contributing to improved efficiency, effectiveness, accountability and service delivery during and beyond the project life by building capacities, system and processes.

Disbursement Linked Indicator 4 (DLI -4) aims for improvements in own source revenue collection system that encourages the City Local Government (CDGs), Development Authorities (DAs) and Service providers (WASAs) to bring improved systems for revenue enhancement. This DLI is linked with the initiative of WASAs to carry out the Energy Audit for resources conservation and efficiency to improved service delivery, accountability and own source revenue.

One of the proposed actions & initiatives to enhance revenue was to conduct energy audit of WASAs to reduce the power cost by various systematic analysis of the energy use and finding out the energy management opportunities. WASAs each year incur significant cost. It was **Rs. 4,697 million** in 2014 year for energy/Electricity bills, with an installed capacity of approximately 131 MW for 5,663 Million Gallons per Day (water management), which can be reduced through detailed energy audit and implementing its findings.

In the context of existing scenario energy audit of WASAs is a technical and efficient way to obtain energy analysis and savings through improvements that optimize pumping systems of tube well stations and disposal stations to operate efficiently with significant cost saving.

The Urban Planning and Management Services Unit, Pvt. Ltd. has assigned NEC Consultants Pvt. Ltd to conduct energy audits of WASAs in Punjab in five major cities of Lahore, Rawalpindi, Faisalabad, Multan and Gujranwala.

This is the energy audit report of **Jhang Branch Canal of Faisalabad city**.

### 1.2 Methodology

The primary and secondary sources were used to collect data for different WASAs and pumps installed there. The Urban Unit provided information and contact detail of all the WASAs. An energy audit report template was developed to collect field data from each WASA subdivision. Prior to start the on field measurements of each subdivision, meetings were conducted with the respective WASA management and briefed them about the activity. The technical team then collected data by on field measurements of each pump and recorded in their energy audit report template. On the basis of this energy audit report template, The Urban Unit also developed Android based software to record data of each pump online. This data was also recorded on line in this Android based application.

On the basis of field measurements, efficiency of the pumping system was calculated and

energy efficiency opportunities were identified.

### 1.3 Scope

The scope of the this assignment is to conduct energy audits of about 1,600 fresh water supply and wastewater disposal pumps installed at different WASA stations in five major cities of Lahore, Rawalpindi, Multan, Faisalabad and Gujranwala. The detail of these pumps is given in Table-1.

**Table-1: Detail of WASAs Pumps**

WASA	Population Served (Million)	Total Water Connections	Total Sewerage Connections	Total Supply Stations	Total Disposal Stations	Total No. of Pump Sets
WASA Lahore	5.48	587,595	583,532	491	99	776
WASA Gujranwala	0.54	29,375	97,236	66	23	112
WASA Faisalabad	1.55	110,452	217,002	87	43	222
WASA Multan	1.2	43,996	175,615	102	21	161
WASA Rawalpindi	1.17	92,468	38,437	362	-	362
<b>Total</b>	<b>9.94</b>	<b>863,886</b>	<b>1,111,822</b>	<b>1,108</b>	<b>186</b>	<b>1,633</b>

The efficiency of each pumping system was evaluated and energy efficiency improvement opportunities were identified for those pumping systems whose efficiencies were not at required level. The detail of reports prepared is as under:

- The energy audit report of each pump was prepared.
- On the basis of each pump report, summary report of findings of each WASA subdivision/zone was prepared.
- On the basis of each subdivision/zone summary report, one consolidated report of each city for energy efficiency improvement opportunities of the WASAs was prepared.

## 2.0 Energy Audit Findings



There are 22 WASA water supply stations in Jhang Branch Canal of Faisalabad city. The detail of these stations along with pumps installed capacity and actual discharge is given in Table-2:

**Table-2: Detail of Jhang Branch Canal**

#	WASA Station	No. of Water Supply Pumps Installed	Installed Capacity (Cusec)	Actual Discharge (Cusec)
1	TW No.03	01	1.96	1.65
2	TW No.05	01	1.96	1.61
3	TW No.06	01	1.96	1.63
4	TW No.07	01	1.96	1.84
5	TW No.08	01	1.96	1.57
6	TW No.09	01	1.96	1.72
7	TW No.10	01	1.96	2.06
8	TW No.11	01	1.96	1.89
9	TW No.12	01	1.96	2.00
10	TW No.13	01	1.96	1.80
11	TW No.14	01	1.96	1.75
12	TW No.15	01	1.96	1.71
13	TW No.16	01	1.96	2.48
14	TW No.17	01	1.96	1.72
15	TW No.18	01	1.96	1.71
16	TW No.19	01	1.96	1.71
17	TW No.20	01	1.96	1.56
18	TW No.21	01	1.96	1.80
19	TW No.22	01	1.96	1.95
20	TW No.23	01	1.96	1.53
21	TW No.24	01	1.96	1.69
22	TW No.25	01	1.96	1.74
<b>Total</b>		<b>22</b>	<b>43.12</b>	<b>39.12</b>

The installed capacity of WASA tube wells of Jhang Branch is 24.08 million m<sup>3</sup> per annum whereas actual discharge is 21.85 million m<sup>3</sup> per annum, for average 15 hours per day operation and 365 days per year. This actual discharge is about 9% lesser than the installed capacity.

## 2.1 Pumping System Efficiency

Pumping plant performance can be classified as “Low”, “Fair”, “Good”, or “Excellent” by referring to the following table, which is based upon the results of thousands of pump tests conducted by Pacific Gas & Electric Company, USA. This classification is used to categorize WASA pumps.

**Table-3: Typical Overall Pumping System Efficiency Classification**

Motor HP	Low	Fair	Good	Excellent
3-7.5	<44.0	44-49.9	50-54.9	>54.9

10	<46.0	46-52.9	53-57.9	>57.9
15	<47.1	48-53.9	54-59.9	>59.9
20-25	<48.0	50-56.9	57-60.9	>60.9
30-50	<52.1	52.1-58.9	59-61.9	>61.9
60-75	<56.0	56-60.9	61-65.9	>65.9
100	<57.3	57.3-62.9	63-66.9	>66.9
150	<58.1	58.1-63.4	63.5-68.9	>68.9
200	<59.1	59.1-63.8	63.9-69.4	>69.4
250	<59.1	59.1-63.8	63.9-69.4	>69.4
300	<60	60-64.0	64.1-69.9	>69.9

Source: Pacific Gas & Electric Company, USA


The detail of pumping system efficiency and motor loading of each WASA station is given in Table-4. The calculations for the efficiency determination are given in the energy audit report of each pump in **Annexure-1**.

**Table-4: Detail of Motor Loading and Pumping System Efficiency**

WASA Station	Motor Load (%)	Pumping System Efficiency (%)	Pumping System Efficiency Rating
TW No.03	79	81	EXCELLENT
TW No.05	76	82	EXCELLENT
TW No.07	87	74	EXCELLENT
TW No.08	82	67	EXCELLENT
TW No.10	92	82	EXCELLENT
TW No.11	87	79	EXCELLENT
TW No.12	82	85	EXCELLENT
TW No.13	79	81	EXCELLENT
TW No.14	81	77	EXCELLENT
TW No.15	80	74	EXCELLENT
TW No.16	84	81	EXCELLENT
TW No.17	84	67	EXCELLENT
TW No.18	81	78	EXCELLENT
TW No.19	82	80	EXCELLENT
TW No.20	76	79	EXCELLENT
TW No.21	77	86	EXCELLENT
TW No.22	79	84	EXCELLENT
TW No.23	85	69	EXCELLENT
TW No.24	88	74	EXCELLENT
TW No.25	85	79	EXCELLENT
TW No.09	87	64	GOOD
TW No.06	89	66	GOOD

All (100%) the tube wells are under excellent and good category of pumping system efficiency as illustrated in Fig-1.

**Figure-1: Pumping System Efficiency Category**



## 2.2 Electricity Consumption Trend


The detail of annual water discharge and correspondingly electricity consumption and unit electricity consumption of each WASA station is given in Table-5.

**Table-5: Detail of Water Discharge and Electricity Consumption**

#	WASA Station	Annual Water Discharge (m <sup>3</sup> )	Annual Electricity Consumption (kWh)	Unit Electricity Consumption (kWh/m <sup>3</sup> )
1	TW No.3	1,042,440	294,238	0.28
2	TW No.5	897,900	250,999	0.28
3	TW No.6	848,260	274,508	0.32
4	TW No.07	960,680	202,071	0.21
5	TW No.08	876,000	203,661	0.23
6	TW No.09	957,249	216,505	0.23
7	TW No.10	1,839,600	365,049	0.20
8	TW No.11	1,056,675	216,138	0.20
9	TW No.12	1,191,360	180,054	0.15
10	TW No.13	1,068,720	174,182	0.16
11	TW No.14	1,039,520	177,314	0.17
12	TW No.15	1,016,160	176,139	0.17
13	TW No.16	1,477,520	184,046	0.12
14	TW No.17	1,022,000	185,925	0.18
15	TW No.18	1,079,670	190,475	0.18
16	TW No.19	1,073,465	191,307	0.18
17	TW No.20	1,044,630	189,350	0.18
18	TW No.21	1,000,064	158,159	0.16
19	TW No.22	1,089,525	162,929	0.15
20	TW No.23	854,100	211,092	0.25
21	TW No.24	941,700	217,954	0.23
22	TW No.25	969,075	210,817	0.22
<b>Total</b>		<b>23,346,313</b>	<b>4,632,912</b>	<b>0.20</b>

Total annual energy cost of Jhang Branch Canal is about Rs. 60 million. The unit electricity consumption trend for each WASA station is illustrated in Fig-2.

**Figure-2: Unit Electricity Consumption Trend (Tube Wells)**



### **2.3 Pumping System Efficiency Improvement Potential**

All the tube wells are under excellent and good category of pumping system efficiency. No pump is required any intervention to improve its efficiency.

### **2.4 Interventions for the Improvement of WASA Stations**

Energy audit activity of Jhang Branch Canal revealed that there are certain areas of electrical, mechanical and housekeeping which needs improvement. Table-6A & B presents detail of interventions and investment requirement in each WASA station for better and safe operation of WASA station.

About Rs. 1.365 million are required to improve WASA stations of Jhang Branch Canal of Faisalabad city.

**Table-6A: Interventions & Investment Required in WASA Stations- Jhang Branch Canal**

Intervention	WASA Stations														
	TW No.3	TW No.5	TW No.6	TW No.7	TW No.8	TW No.9	TW No.10	TW No.11	TW No.12	TW No.13	TW No.14	TW No.15	TW No.16	TW No.17	TW No.18
<b>Electrical</b>															
Install VFD	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Install hour meter	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Replace ampere meter								x						x	
Replace volt meter								x	x	x			x		
Replace over current relays															
Replace over voltage relay															
Install/maintain PFI plant															
Install/connect capacitors at PFI plant															
Install PFI control/relay															
Install/replace motor terminal box /Improve open and loose motor connection															
Improve panel condition															
Improve wiring condition															
Replace de-rated capacitors															
Relocate panel away from bore hole															
Replace electrical motor															
Install fan in the panel															
Replace PFI HRC fuses															
Replace PFI display meter			x	x	x	x	x	x	x	x	x	x	x	x	x
Correct date & time of electrical meter															
Replace/correct electrical meter															
Replace change over															
Replace main circuit breaker															
<b>Mechanical</b>															
Replace damaged/install new flow															

Intervention	WASA Stations														
	TW No.3	TW No.5	TW No.6	TW No.7	TW No.8	TW No.9	TW No.10	TW No.11	TW No.12	TW No.13	TW No.14	TW No.15	TW No.16	TW No.17	TW No.18
meter															
Replace damaged/install new digital pressure gauge	x	x	x	x	x	x				x		x			x
Control gland leakage	x	x	x	x			x	x			x				x
Make operational/install new chlorinator															
Maintain ratchet plate															
Adjust impeller															
Repair & maintenance of pump															
Replace existing pumping system															
Maintain/install new non return valve															
<b>Housekeeping</b>															
Improve general housekeeping															
Install shades on motor & pump															
Rain protection of motor & pump															
Fix panel properly															
Proper support of discharge pipeline															
Maintain monthly record of fuel consumption															
<b>Station Wise Investment (M. Rs)</b>	0.100	0.090	0.080	0.090	0.080	0.080	0.030	0.040	0.025	0.085	0.030	0.080	0.025	0.025	0.090
<b>Annual Saving (M. Rs)</b>	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
<b>Payback (Year)</b>	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

**Table-6B: Interventions & Investment Required in WASA Stations-Jhang Branch Canal**

Intervention	WASA Stations							
	TW No.19	TW No.20	TW No.21	TW No.22	TW No.23	TW No.24	TW No.25	
<b>Electrical</b>								
Install VFD	x	x	x	x	x	x	x	
Install hour meter	x	x	x	x	x	x	x	
Replace ampere meter					x	x		
Replace volt meter	x	x	x	x	x	x	x	
Replace over current relays								
Replace over voltage relay								
Install/maintain PFI plant								
Install/connect capacitors at PFI plant								
Install PFI control/relay								
Install/replace motor terminal box								
Improve panel condition								
Improve wiring condition								
Replace de-rated capacitors								
Relocate panel away from bore hole								
Replace electrical motor								
Install fan in the panel								
Replace PFI HRC fuses								
Replace PFI display meter	x	x	x	x	x	x	x	
Correct date & time of electrical meter	x							
Replace/correct electrical meter								
Replace change over								

Intervention	WASA Stations							
	TW No.19	TW No.20	TW No.21	TW No.22	TW No.23	TW No.24	TW No.25	
Replace main circuit breaker								
<b>Mechanical</b>								
Replace damaged/install new flow meter								
Replace damaged/install new digital pressure gauge	x	x			x			
Control gland leakage	x			x	x	x	x	
Make operational/install new chlorinator								
Maintain ratchet plate								
Adjust impeller								
Repair & maintenance of pump								
Replace existing pumping system								
Maintain/install new non return valve								
<b>Housekeeping</b>								
Improve general housekeeping								
Install shades on motor & pump								
Rain protection of motor & pump								
Fix panel properly								
Proper support of discharge pipeline								
Maintain monthly record of fuel consumption								
<b>Station Wise Investment (M. Rs)</b>	0.095	0.085	0.025	0.035	0.100	0.040	0.035	
<b>Annual Saving (M. Rs)</b>	--	--	--	--	--	--	--	



Intervention	WASA Stations							
	TW No.19	TW No.20	TW No.21	TW No.22	TW No.23	TW No.24	TW No.25	
<b>Payback (Year)</b>	--	--	--	--	--	--	--	

# ANNEXURE-1

## Energy Audit Reports